

Approval Number: 1912554
Test Report: M106949A & B



Water Regulations Advisory Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

1st June 2020

Isoil Industria Spa
Via F. Ili Gracchi n.27,
20092 Cinisello Balsamo (MI),
Italy

WATER REGULATIONS ADVISORY SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYTETRAFLUOROETHYLENE (PTFE) - COMPONENTS.

5294

'FluteckTMP1000 & FluteckTMP1500'. White coloured, extruded, disc shaped PTFE components. For use with water up to 85°C.

APPROVAL NUMBER: 1912554

APPROVAL HOLDER: ISOIL INDUSTRIA SPA

The Scheme reserves the right to review approval.

Approval 1912554 is valid between December 2019 and December 2024

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wras.co.uk/directory

Yours faithfully

A handwritten signature in black ink, appearing to read 'Jason Furnival', written over a light blue circular stamp.

Jason Furnival
Approvals & Enquiries Manager
Water Regulations Advisory Scheme